

REQUEST FOR INFORMATION



Job No: XXXXXX

Project Name: SAMPLE PROJECT - Example Warehouse Extension

RFI No: 01

Date: 02/03/2026

Addressed To

Example Builder Pty Ltd

Email

rfi@example.com

Issued For

☒ Action☐ Information

Regarding - Base Plate Size Conflict – Column Schedule vs Detail 3


Reference Doc - S-101 Column Schedule, S-201 Detail 3 Area - Grid A / 1-6

Question

The column schedule on S-101 lists base plate BP1 as **300x300x20** with 4/M20 cast-in bolts. Detail 3 on S-201 shows the same columns (Grid A / 1-6) with a **350x350x25** base plate and 4/M24 cast-in bolts. Please confirm which size governs.


SKETCH - BASE PLATE BP1 (not to scale)

S-101 SCHEDULE: BP1



CONFLICT

S-201 DETAIL 3: BP1



Proposed solution: Model BP1 as 350x350x25 with 4/M24 cast-in bolts per Detail 3 (larger plate is conservative) and update the column schedule at the next revision. Please confirm or advise otherwise.

Response

Reply Required by: 04/03/2026

Raised by: RDM Drafting

Please note: Replies received after the required date may directly impact the agreed completion date of drawings.